


301EM-20 WIRING DETAILS



VA301C	
relay 1:	ALARM LEVEL A
relay 2:	ALARM LEVEL B
relay 3:	SPARE
relay 4:	FAULT

Wiring VA301C		
Channel	Wire gage	Distance (ft)
1	14 AWG	1000
2	14 AWG	1000
3	14 AWG	1000

Communication Wire Gauge: 24-2 AWG (Belden 9841)
 Twisted and shielded cable 2000 feet (600 m) per channel
NOTE: CONDUIT ENTRIES ARE LOCATED AT THE BOTTOM OF THE ENCLOSURES.

See the wiring details on the sheets included.
 Consult the user guide for complete information.
 The Honeywell products must be easy to access for maintenance.

Type of gas:	R134A				
Alarm level A	100 PPM				
Alarm level B	500 PPM				
Alarm level C	900 PPM				

Project:	301REM-20 WIRING DETAILS
Client:	
Drawing number:	
Rev.:	Date: MAY 26, 2011
Drawn by:	SJI
# Command:	N/A
Page:	(1/1)

Honeywell Analytics

405 Barclay Boulevard
 Lincolnshire, IL 60069
 Tel.: 1-800-563-2967
 Fax.: 1-888-967-9938
 www.honeywellanalytics.com