



Certificate of Compliance

Certificate: 2470271

Master Contract: 171882

Project: 70009908

Date Issued: August 28, 2014

Issued to: Honeywell Analytics Ltd.

Hatch Pond House
4 Stinsford Rd
Nuffield Industrial Estate
Poole, Dorset BH17 0RZ
United Kingdom
Attention: Richard King

The products listed below are eligible to bear the CSA Mark shown



Zahra Amini

Issued by: Zahra Amini

PRODUCTS

CLASS 4828 01 - SIGNAL APPLIANCES - - Combustible Gas Detection Instruments-For Hazardous Locations

Class 1, Groups B,C,D

-Model 705 Combustible Gas Sensor Assembly, Part Number 705-A-1733; for use with Certified Model 5700 Gas Detection System and Model 1051.

Note: Rack and Wall mounted units are for use in non-hazardous locations and rack assemblies are to be installed in appropriate enclosures subject to acceptance of local inspection authority having jurisdiction.

Class 4828 02 SIGNAL APPLIANCES – Toxic Gas Detection Instruments- For Hazardous Locations

Class 1, Groups B,C,D

Model 705 Toxic Gas Sensor Assembly, Part No 705-A-**** (**** varies with gas type), rated 35Vdc max, 100mA max.



Certificate: 2470271

Master Contract: 171882

Project: 70009908

Date Issued: August 28, 2014

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No 0-M1991	General Requirements - Canadian Electrical Code, Part II
CSA Standard C22.2 No 0.4-M1982	Grounding and Bonding
CSA Standard C22.2 No 30-M1986	Explosion Proof Enclosures for Use in Class I, Hazardous Locations (as applicable)
CSA Standard C22.2 No 142-M1987	Process Control Equipment
CSA Standard C22.2 No 152-M1984	Combustible Gas Detection Instruments