



Certificate of Compliance

Certificate: 70025950

Master Contract: 171882

Project: 70025950

Date Issued: 2015-05-26

Issued to: Honeywell Analytics Ltd
4 Stinsford Road
Nuffield Estate
Poole
BH17 0RZ
United Kingdom
Attention: Mr. Colin Hydes

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by:

L Pall

PRODUCTS

CLASS – 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Location

Ex nA nC IIC T4
Class I, Division 2, Groups A, B, C and D

CLASS – 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations - Certified to US Standards

AEx nA nC IIC T4
Class I, Division 2, Groups A, B, C and D

Touchpoint Pro Relay Output Module (ROM), DIN rail mounted, type n and non-incendive, 18-32V dc, Ta = -40°C to +70°C.

CONDITIONS OF ACCEPTABILITY

The equipment shall be installed in an Ex e or Ex n approved enclosure, or an equivalent tool-secure enclosure approved for Div 2 use, that provides an ingress protection of at least IP54.



Certificate: 70025950

Master Contract: 171882

Project: 70025950

Date Issued: 2015-05-26

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No. 61010-1-04	Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements - Third Edition
C22.2 No. 213-M1987 (R2008)	Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations
CAN/CSA-C22.2 No. 60079-0:07	Explosive Atmospheres - Part 0: Equipment - General requirements
CAN/CSA-C22.2 No. 60079-15:12	Electrical apparatus for explosive gas atmospheres - Part 15: Construction, test and marking of type of protection “n” electrical apparatus
C22.2 No 152 M-1984	Combustible gas detection instruments
FM 6310 / 6320 2001	Combustible gas detectors
UL Std. No. 61010-1 (2nd Edition)	Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements
ANSI/ISA-12.12.01-2013	Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
ANSI/UL 60079-0:2013	Explosive Atmospheres - Part 0: Equipment - General Requirements
ANSI/UL 60079-15:2013	Explosive Atmospheres - Part 15: Equipment protection by type of protection “n”